

February 5, 2004

ECOLOGICAL TANKS, INC.
JAMES K. CRAFT
2247 HWY 151 N
DOWNSVILLE LA 71234

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: ECOLOGICAL TANKS, INC.
Product Name: AQUASAFE
Model Number(s): AS1500 and AS1500EZ (1500 GPD)
Product File No: 20030574

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The maximum daily wastewater flow which may discharge through this product is 1500 gallons per day.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L.
- This product must be installed with the optional 20" diameter Poly Riser terminating at or above finished grade.
- The maximum depth of the treatment tank of this product is 30 inches.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ECOLOGICAL TANKS, INC.

Page 2

February 5, 2004

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov